

**KIMBERLY A.
DELLASTATIOUS, P.A.**

A R C H I T E C T

Addendum #2

Date: 10.19.21
To: All Registered Bidding Contractors PAGE: 1 OF 1
Cc: Owner
From: Kimberly A. Dellastatious, PA
RE: PBCHA 4751 S Dyson Circle Burn Unit #KD-21724
Priority: High

SUBJECT: Addendum No. 2 to the Construction Documents and Specifications for
the **PBCHA 4751 S Dyson Circle Burn Unit #KD-21724**

1. The wall mounted light at the exterior wall at the rear door and at the front door is tagged incorrectly. It is tagged as a L7 and it should be tagged as a L8. This L8 fixture is by "Hubbell Outdoor Lighting NRG-356L-5K-U-PC6" To be ordered with photocell accessory.

Please attach this Addendum #2 cover sheet to your bid proposal package and also identify this Addendum #2 on sheet 00200-2 of your bid proposal.

THANK YOU, KIMBERLY DELLASTATIOUS